



POSITIVE DISPLACEMENT BLOWER SPECIFICATIONS

- FACTORY PRESET PRESSURE RELIEF VALVE
- FLOW CHECK VALVE
- BRASS GATE ISOLATION VALVE
- 3/16" THICK A-36 STEEL BLOWER BASE (BLASTED AND PRIMED WITH 4-5 MIL DFT EPOXY PRIMER WITH URETHANE TOPCOAT)
- WEG 22 NEMA PREMIUM ELECTRIC MOTOR - 1.25 SERVICE FACTOR
- EXHAUST SILENCER
- GARDNER DENVER (SUTORBILT) LEGEND PD BLOWER
- 14 GAGE 304L UPPER STAINLESS STEEL ENCLOSURE (BLASTED AND COATED WITH URETHANE DTM PAINT)
- SINGLE PHASE ODP MOTORS AVAILABLE UPON REQUEST



DP WATER
SOLUTIONS

Contact Us:

3714 U.S. Hwy 82 West, Tifton,
GA 31793

Tel: 229-387-0303

Website: www.dpiwater.com

Email: danm@dpiwater.com